



REV.	DATE	BY	CHKD.	PB	RP	APPD.	DESCRIPTION
1	23.03.09	RU	PB	RP	RP	RP	ISSUED FOR INFORMATION
A3	DO NOT SCALE IF IN DOUBT ASK ALL DIMENSIONS IN MM		GENERAL TOLERANCES (unless noted otherwise)		GRP FABRICATED MACHINED	LINEAR	$\pm 5mm$ $\pm 2mm$ $\pm 0.5^\circ$ $\pm 0.2^\circ$ $\pm 0.1^\circ$
THIS DRAWING IS THE PROPERTY OF CONDER SOLUTIONS Ltd. AND IS NOT TO BE COPIED IN PART OR WHOLE WITHOUT PERMISSION							

IMPORTANT INVERT LEVEL NOTE (RIBBED TANKS ONLY):
 The inlet and outlet Invert Level(IL) shown on this drawing is to internals of the shell unless otherwise stated.
 For Invert level to the outside of the shell ribs, see the conversion below:
 $\phi 1.0m, 1.2m, 1.5m, 1.8m, 2.5m$ IL+50mm ('X')
 $\phi 3.0m, 4.0m$ IL+75mm ('X')

TANKS SUPPLIED WITH LOOSE SHAFTS DO NOT COME SUPPLIED WITH A FIXING KIT.
 THIS IS THE RESPONSIBILITY OF THE SITE CONTRACTOR.



INNER TANK SHELL
 DETAIL 'Y'



1ST ANGLE PROJECTION


TITLE

ASP12

SEWAGE TREATMENT PLANT

DRAWN BY	CHKD.	APPD.	SCALE	DRAWING No.	REVISION
RU	PB	RP	NTS	ASP12 SALES	1

DATE	DATE	DATE
23.03.09	23.03.09	23.03.09



conder
 ENVIRONMENTAL SOLUTIONS