



TITLE
CU2.3000

DRAWN BY
J. Ellison

DATE
04/01/2022

CUSTOMER
CUSTOMER

NOTE:
All tanks must be fully supported on a flat level & continuous foundation providing structural support to the tank when full to maximum operating capacity. It is essential that the user refers to the conditions of installation document prior to the installation of the tank. Under no circumstances should the tank body be used to provide support to pipework and ancillary items. The tank lid is a structural part of the tank and must be in place and fitted correctly when water is contained within the tank.

ALL DIMENSIONS +/- 5mm
UNLESS OTHERWISE STATED

DESCRIPTION:
CU2.3000-AG Airgap Combination Unit

A4

ALL DIMENSIONS IN MM - DO NOT SCALE

DATE	VERSION	NOTES
04/01/2022	A	FIRST ISSUE

TANK SPECIFICATION :

WET COMPARTMENT	1300 x 1800 x 1800mm
DRY COMPARTMENT	1200 x 1800 x 1800mm
EXTERNAL DIMENSIONS	2660 x 1960 x 1918mm
NOMINAL CAPACITY	4200 Litres
DRY WEIGHT	XXX KG
INSULATION THICKNESS	25mm
MATERIAL	GRP

TANKS DIRECT

SCALE: 1:40

SHEET 1 OF 1